

**HARRISBURG AREA COMMUNITY COLLEGE  
REQUEST FOR PROPOSAL  
#08-09  
LAUNDRY EQUIPMENT  
ADDENDUM #1  
ANSWERS TO QUESTIONS**

**AUGUST 28, 2007**

**Question 1:** What kind of Support Warranty?

**Answer 1:** What is the cost of maintenance for the equipment after warranty.

**Question 2:** Please clarify specifications on the washer. There is no 205 voltage and there is no natural gas fired washer extractor?

**Answer 2:** The electrical spec is 208 – 3 phase. The specification on the Washer / Extractor will be ELECTRIC. The specification on the Drying Tumbler and Ironer will be NATURAL GAS FIRED.

**Question 3:** Detail the type of training you require?

**Answer 3:** It is expected that upon completion of installation, that instructions be given on the operation of the units, such start up of equipment, operation of the equipment, etc.

**Question 4:** Will there be a mandatory site visit? If not who do I contact for a site visit?

**Answer 4:** HACC is not requiring a mandatory site visit for this project. If your firm would like to visit HACC, you may contact Dan Jusko at 717-780-2649. The final selected site has not been determined at this time. There are 3 sites being looked at. One site would be located on the second floor of Mumma Hall. The other two sites will be located at ground level.

Because there maybe a second floor installation, the Bidders are requested to break out the cost for a hard mount and a soft mount installation. In addition, if there is a difference in cost for a hard mount installation versus a soft mount installation, the Bidders should present the cost for each type of installation.

**CHANGE IN PROPOSAL DUE DATE:**

**NOTE: BASED ON THE REQUESTS FOR A SITE VISIT, HACC IS MAKING AVAILABLE TO THOSE FIRMS WHO WOULD LIKE TO SCHEDULE A SITE VISIT WITH MR. JUSKO. BY ENTERTAINING THIS REQUEST, HACC IS MODIFYING THE**

**“PROPOSAL DUE DATE” FROM SEPTEMBER 4, 2007 TO  
SEPTEMBER 12, 2007 BY 11:30AM.**