



## **ADDENDUM #1 R**

**June 12, 2009**

Re: HACC, Central Pennsylvania's Community College  
Renovations to York Campus CyTec Facility  
Solicitation # 09-38 A – Contract No. 2 HVAC and Controls  
Solicitation # 09-38 B – Contract No. 3 Electrical

From: Eastern pcm, LLC  
Construction Manager – HACC  
212 Locust Street, Suite 604  
Harrisburg, PA 17110

To: All Planholders

---

This Addendum is hereby made part of the Plans and Specifications dated May 29, 2009 for the above referenced project. The provisions of this Addendum are intended to supplement the provisions of the Plans and Specifications and/or supersede them where contradictory thereto.

This Addendum contains changes to the requirements of the Plans and Specifications. Such changes shall be incorporated into the Plans and Specifications and shall apply to work with the same meaning and force as if they had been included in the original Plans and Specifications. Where this Addendum modifies a portion of a paragraph or phrase of the Project Manual, the remaining unmodified portion of the paragraph or phrase shall remain in force.

The conditions and terms of the Plans and Specifications shall govern work described in this Addendum. Whenever the conditions of work, or the quality or quantity of materials or workmanship are not fully described in this Addendum, the conditions of work etc. included in the Plans and Specifications for similar items of work shall apply to the work described in this Addendum. If no similar items of work are included in the Plans and Specifications, the quality of material and workmanship shall be subject to the written acceptance of the Architect.

### **1.1 CHANGES TO PROJECT MANUAL**

a. Section 01125 – Summary of Contracts

ADD the following to Page 5, Article 1.6.A Contract No. 1 General Trades

11. Coordinate with other Contractors and make safe all electrical components prior to demolition.
12. Provide, install and maintain provisions for temporary power and lighting throughout the facility during the course of construction. Power source shall be existing main distribution panel or sub panel and shall be OSHA compliant.

b. Section 01125 – Summary of Contracts

DELETE the following from Article 1.6.C Contract No. 3 Electrical

Line 1 and Line 3

**1.2 PRE-BID MEETING MINUTES**

Meeting minutes from the Pre-Bid Meeting held on June 4, 2009 are attached and are a part of this Addendum. In the event of a conflict between the information contained in the Pre-Bid Meeting Notes and the Drawings, Specifications and responses to questions contained in this Addendum, the latter shall take precedence.

**END OF ADDENDUM**