



ADDENDUM #2

May 11, 2009

Re: HACC, Central Pennsylvania's Community College
Biology Lab Relocation – Hall Tech
HACC Solicitation #09-39

From: Eastern pcm, LLC
Construction Manager – HACC
212 Locust Street, Suite 604
Harrisburg, PA 17101

To: All Plan Holders

This Addendum is hereby made part of the Contract Documents for the above referenced project. The provisions of this Addendum are intended to supplement the provisions of the Contract Documents and/or supersede them where contradictory thereto.

This Addendum contains changes to the requirements of the Project Manual and Drawings. Such changes shall be incorporated into the Contract Documents and shall apply to work with the same meaning and force as if they had been included in the original Contract Documents. Where this Addendum modifies a portion of a paragraph or phrase of the Project Manual, the remaining unmodified portion of the paragraph or phrase shall remain in force.

The conditions and terms of the Project Manual shall govern work described in this Addendum. Whenever the conditions of work, or the quality or quantity of materials or workmanship are not fully described in this Addendum, the conditions of work etc. included in the Project Manual for similar items of work shall apply to the work described in this Addendum. If no similar items of work are included in the Project Manual, the quality of material and workmanship shall be subject to the written acceptance of the Architect.

2.1 CLARIFICATIONS

a. **Q:** Drawing A1.1. Note #15 Smart Classroom Station, HACC will be providing two (2) Smart Classroom Stations? We are only taking one (1) from Penn Center, but at Hall Tech Building we have one station each in 206 and 207.

A: Contractor is responsible to relocate one (1) Smart Classroom Station from 3 Penn Center to Hall Tech Building Room 206. Contractor to install existing power pole at each location and provide power for each Smart Classroom Station as shown on Drawing E1.1. HACC will install the Smart Classroom Work Station in Hall Tech Room 207.

b. **Q:** Will the bid date be extended?

A: No, the bid due date will not be extended and remains 1:00pm, Tuesday May 12, 2009 at Whitaker Hall, Room 130.

c. **Q:** Regarding the lighting, alternate one would like a price to re lamp and clean existing fixtures, but I do not see a drawing that shows the existing fixtures. Please advise.

A: There is no drawing showing the existing lighting layout. Information may be obtained via a site visit.

d. **Q:** Does the new biology lab sanitary system need to be chemical waste piping? In the specs on 15150-1, it is stated to see Division 15 Section "Chemical Waste Piping" for chemical waste and vent piping systems.

A: There is no "chemical waste piping" included in this project. Please disregard the reference noted in Item 1.1 Summary, paragraph B.

END OF ADDENDUM