



**ADDENDUM #1**

**May 12, 2009**

Re: HACC, Central Pennsylvania's Community College  
Gettysburg Monument Sign  
Solicitation # 09-40

From: Eastern pcm, LLC  
Construction Manager – HACC  
212 Locust Street, Suite 604  
Harrisburg, PA 17101

To: All Plan Holders

---

This Addendum is hereby made part of the Contract Documents for the above referenced project. The provisions of this Addendum are intended to supplement the provisions of the Contract Documents and/or supersede them where contradictory thereto.

This Addendum contains changes to the requirements of the Project Manual and Drawings. Such changes shall be incorporated into the Contract Documents and shall apply to work with the same meaning and force as if they had been included in the original Contract Documents. Where this Addendum modifies a portion of a paragraph or phrase of the Project Manual, the remaining unmodified portion of the paragraph or phrase shall remain in force.

The conditions and terms of the Project Manual shall govern work described in this Addendum. Whenever the conditions of work, or the quality or quantity of materials or workmanship are not fully described in this Addendum, the conditions of work etc. included in the Project Manual for similar items of work shall apply to the work described in this Addendum. If no similar items of work are included in the Project Manual, the quality of material and workmanship shall be subject to the written acceptance of the Architect.

**1.1 CHANGES TO DRAWINGS**

a. Drawing C-1, Section

**CHANGE** Galvanized Steel Bar Grating to Aluminum Bar Grating

**CHANGE** note to read: "11.5" x 3.5" concrete cap to match existing precast cap at building."

b. Drawing C-1, Wall Notes

**ADD** Note 5 as follows:

5. Abbey Blend – Contractor to submit sample for approval  
Basis of design: Nitterhouse J91, J15, H46 in equal proportions

**END OF ADDENDUM**