



NOTES:

CONCRETE PAVERS SHALL MEET THE REQUIREMENTS OF ASTM C936, STANDARD SPECIFICATION FOR SOLID INTERLOCKING CONCRETE PAVING UNITS.

BEDDING SAND SHALL CONFORM TO THE GRADING REQUIREMENTS OF ASTM C33 OR CSA A23.1. DO NOT USE MASON SAND. THE SAND SHOULD BE SCREEDED TO A CONSISTENT, EVEN THICKNESS BETWEEN 1" AND 1-1/2"

AFTER PAVERS ARE PLACED COMPACT INTO THE BEDDING SAND WITH A PLATE COMPACTOR. THE COMPACTOR SHALL HAVE A MINIMUM FORCE OF 4000 LB (18 KN) AND FREQUENCY OF 75 - 100 HZ. AFTER THE PAVERS ARE COMPACTED, SAND SHALL BE SWEEPED AND VIBRATED INTO THE JOINTS UNTIL THEY ARE FULL. JOINT SAND SHOULD CONFORM TO THE GRADING REQUIREMENTS OF ASTM C144 OR CSA-A179.

NOT TO SCALE



200 Airport Road, Capital City Airport
 New Cumberland, PA 17070
 717-901-7055 Fax 717-901-7059

TITLE:
**CONCRETE PAVER SECTION WITH
 PLASTIC EDGE RESTRAINT**

HACC YORK SIDEWALK ADDITION

DRAWING NO.

1

DEC 1, 2009