



ADDENDUM #6

March 4, 2011

Re: Harrisburg Area Community College
Public Safety Center – Law Enforcement Complex & Site Improvements
Solicitation # 11-13

From: Eastern PCM, LLC
Construction Manager – HACC
645 N. 12th Street, Suite 200
Lemoyne, PA 17043

To: All Planholders

This Addendum is hereby made part of the Plans and Project Manual dated January 21, 2011 for the above referenced project. The provisions of this Addendum are intended to supplement the provisions of the Plans and Project Manual and/or supersede them where contradictory thereto.

This Addendum contains changes to the requirements of the Plans and Project Manual. Such changes shall be incorporated into the Plans and Project Manual and shall apply to work with the same meaning and force as if they had been included in the original Plans and Project Manual. Where this Addendum modifies a portion of a paragraph or phrase of the Project Manual, the remaining unmodified portion of the paragraph or phrase shall remain in force.

The conditions and terms of the Plans and Project Manual shall govern work described in this Addendum. Whenever the conditions of work, or the quality or quantity of materials or workmanship are not fully described in this Addendum, the conditions of work etc. included in the Plans and Project Manual for similar items of work shall apply to the work described in this Addendum. If no similar items of work are included in the Plans and Project Manual, the quality of material and workmanship shall be subject to the written acceptance of the Architect.

6.1 ADDENDUM #4 CORRECTION

- A. Answer to question Z on page 13: REVISE to read, “The only topping required is for the training tower and smoke building which is specified in a separate section.”

6.2 CHANGES TO THE PROJECT MANUAL


A. Section 01125 – Summary of Contracts

- a. Bid Package No. 5 – Specialty Construction & Training Props:

Paragraph E.2.f: DELETE “including unistrut”.

- b. CLARIFICATION: The General Trades contractor is responsible for the unistrut suspension system as indicated on the structural drawings. The Specialty Construction contractor is responsible for any additional mounting systems and structural supports not shown on the structural drawings as needed to support their equipment.

END OF ADDENDUM



Please sign and return this page, via fax, to Eastern PCM, LLC at (717) 233-1666 indicating receipt of this Addendum.

Public Safety Center – Law Enforcement Complex and Site Improvements

Addendum # _____ has been received.

Company: _____
Print Company Name

Received By: _____
Print Name Signature

Date: _____

Please check one:

- _____ We are bidding as a prime contractor
- _____ We are not bidding
- _____ We are a sub-contractor